

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):


Company Name	Antec Group Pty Ltd	Client ID	103379
Company Other Name	Antec Fire	Type of Certification	Product Certification; System 5
Certification Standard	AS/NZS 1841.2-2007 : Portable fire extinguishers - Specific requirements for water type extinguishers		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	27/05/2019	Certification Expiry Date	15/06/2024
Certificate Issue Date	2/02/2017	Certificate Last Update Date	4/09/2020

APPROVED COMPANY/SITE ADDRESS(ES):
9 Chicago Ave Blacktown NSW 2148 Australia

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager



Unique Certificate Code: **19C201871EDD53EACA2585A1000DD704**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®

JAS-ANZ



WWW.JAS-ANZ.ORG/REGISTER



Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
1000-3001	9.0L Water	Antec Fire	9.0 L Water, Rating: 3A, FERN: 3379.02-100	1/07/2020

Comments:

End of the document



Certification Manager