

# Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	<b>Antec Group Pty Ltd</b>	Client ID	<b>103379</b>
Company Other Name	<b>Antec Fire</b>	Type of Certification	<b>Product Certification; System 5</b>
Certification Standard	<b>AS/NZS 1841.5-2007 : Portable fire extinguishers - Specific requirements for powder type extinguishers</b>		
Scheme	<b>Global-Mark Product Conformance Scheme</b>		
Certification Review Date	<b>27/05/2019</b>	Certification Expiry Date	<b>15/06/2024</b>
Certificate Issue Date	<b>2/02/2016</b>	Certificate Last Update Date	<b>4/09/2020</b>

**APPROVED COMPANY/SITE ADDRESS(ES):**  
**9 Chicago Ave Blacktown NSW 2148 Australia**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**



Unique Certificate Code: **2A37D1D50F3B7932CA2585A1000F6E7E**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®

**JAS-ANZ**



[WWW.JAS-ANZ.ORG/REGISTER](http://WWW.JAS-ANZ.ORG/REGISTER)



**Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:**

*In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).*

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
1000-1001	1.0kg ABE Powder	Antec Fire	1.0 Kg Dry Powder, Rating: 1A:10B:E, FERN: 3379.05-01	1/07/2020
1000-1002	1.5kg ABE Powder	Antec Fire	1.5 Kg Dry Powder, Rating: 2A:20B:E, FERN: 3379.05-02	1/07/2020
1000-1003	2.0kg ABE Powder	Antec Fire	2.0 Kg Dry Powder, Rating: 2A:30B:E, FERN: 3379.05-03	1/07/2020
1000-1004	2.5kg ABE Powder	Antec Fire	2.5 Kg Dry Powder, Rating: 3A:40B:E, FERN: 3379.05-04	1/07/2020
1000-1005	4.5kg ABE Powder	Antec Fire	4.5 Kg Dry Powder, Rating: 4A:60B:E, FERN: 3379.05-05	1/07/2020
1000-1007	9.0kg ABE Powder	Antec Fire	9.0 Kg Dry Powder, Rating: 10A:80B:E, FERN: 3379.05-06	1/07/2020

Comments:

End of the document



**Certification Manager**