

# Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):


Company Name	<b>Antec Group Pty Ltd</b>	Client ID	<b>103379</b>
Company Other Name	<b>Antec Fire</b>	Type of Certification	<b>Product Certification; System 5</b>
Certification Standard	<b>AS/NZS 1841.6-2007 : Portable fire extinguishers - Specific requirements for carbon dioxide type extinguishers</b>		
Scheme	<b>Global-Mark Product Conformance Scheme</b>		
Certification Review Date	<b>27/05/2019</b>	Certification Expiry Date	<b>15/06/2024</b>
Certificate Issue Date	<b>13/08/2017</b>	Certificate Last Update Date	<b>4/09/2020</b>

**APPROVED COMPANY/SITE ADDRESS(ES):**  
**9 Chicago Ave Blacktown NSW 2148 Australia**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**



Unique Certificate Code: **AF925977B82AD43ECA2585A1000FD702**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



[WWW.JAS-ANZ.ORG/REGISTER](http://WWW.JAS-ANZ.ORG/REGISTER)



**Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:**

*In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).*

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
1000-2001	2.0kg Carbondioxide	Antec Fire	2.0 kg Carbondioxide, Rating: 2B:E, FERN: 3379.06-01	1/07/2020
1000-2002	3.5kg Carbondioxide	Antec Fire	3.5 kg Carbondioxide, Rating: 5B:E, FERN: 3379.06-02	1/07/2020
1000-2003	5.0kg Carbondioxide	Antec Fire	5.0 kg Carbondioxide, Rating: 10B:E, FERN: 3379.06-03	1/07/2020

**Comments:**

Construction of extinguishers comply with AS/NZS 1841.1 requirements.

**End of the document**



**Certification Manager**